

```

1 % Test case; Kersting NEV
2 % Kersting, W.H. A three-phase unbalanced line
  model with grounded neutrals
3 % through a resistance. In Proceedings of the
  2008 IEEE Power and Energy
4 % Society General Meeting-PESGM, Pittsburgh, PA,
  USA, 20--24 July 2008;
5 % pp. 12651-12652.
6 % Only two nodes, distance 1.13miles
7 function [db] = loaddatabase
8 db(1)=6000*0.000189393939;%L=section length miles
9 db(2)=0.0244;%GMRf=feet
10 db(3)=0.306;%rf=ohm/mile
11 db(4)=0.721/2;%RDf=inches
12 db(5)=0.00814;%GMRn=feet
13 db(6)=0.5920;%rn=ohm/mile
14 db(7)=0.563/2;%RDn=inches
15 db(8)=60;%f=Hz
16 db(9)=100;%rvd= soil resistivity (ohm-m)
17 db(10)=2.5;%Dab=feet
18 db(11)=4.5;%Dbc=feet
19 db(12)=7.0;%Dac=feet
20 db(13)=5;%Dcn=feet
21 db(14)=3;%Dn=feet
22 db(15)=4.272001872658765;%Dbn=feet
23 db(16)=5.656854249492381;%Dan=feet
24 db(17)=29;%hqa=feet
25 db(18)=29;%hqb=feet
26 db(19)=29;%hqc=feet
27 db(20)=25;%hqn=feet
28 db(20)=3.000*complex(.90,sqrt(1-0.90^2));%S1a (MVA)
29 db(21)=3.500*complex(.95,sqrt(1-0.95^2));%S1b (MVA)
30 db(22)=2.500*complex(.85,sqrt(1-0.85^2));%S1c (MVA)
31 db(23)=500;%MVAsc3
32 db(24)=500;%MVAsc1
33 db(25)=3;%R1/X1
34 db(26)=3;%R0/X0
35 db(27)=12.47;%Nominal voltage (kV)
36 db(28)=0.5;% substation ground mat resistance
  (ohms)
37 db(29)=5.0;% grounding resistance at load (ohms)
38 db(30)=0.0001;% fault resistance (ohms)
39 end

```

```
43 global r3
44 global kVLN
45 kVLL=db(27);%Line to line nominal voltage
46 r1=db(28);%Grounding resistance at bus 1 (GSP)
47 r3=db(29);%Grounding resistance at bus 2 (Load)
48 kVLN=kVLL/sqrt(3);%Line to neutral nominal voltage
49 rf=db(30);%Fault Resistance (ohms)
50
51
52
```